



Namib Consulting <namibconsulting@gmail.com>

RE: INPUT ON THE EIA - MUNITENGE SERVICE STATION

Lucas Maquih <Imaquih@gmail.com>

Wed, Apr 1, 2026 at 3:46 PM

To: Namib Consulting <namibconsulting@gmail.com>

Dear Mr. Mulele.

I hope you have received the feedback from Mr. Sitengu regarding our (KMTC) inputs on the Environmental Impact Assessment (EIA) for the Munitenge Service Station.

The following concerns were raised:

1. The entire site should be interlocked to effectively manage dust from the traffic.
2. Extreme caution must be exercised during all underground construction activities due to the water table being shallow.
3. The area must be fenced off to prevent unauthorised access, particularly from local individuals smoking near the site.

Please let us know if you need further clarification on these points.

Kind regards,

Lucas Kufuna.